

This form clarifies the design direction chosen for *new buildings, additions, and major alterations* to comply with NBC Section 9.36.

All calculations are required to be completed by a competent person (or design professional if NECB used for design) and attached to this form to be accepted for review.

Project Information	
Project Address _____	BPA Number (Office use only) _____
Occupancy Class: _____	Floor Area (m ²): _____
Climate Zone: 7B	
Design Option: <small>(select one)</small>	
<input type="checkbox"/> Prescriptive <small>(See Section A)</small>	<input type="checkbox"/> Trade-Off <small>(See Section B)</small>
<input type="checkbox"/> Performance <small>(See Section C)</small>	

Section A: Prescriptive

HRV / ERV: Yes No

Conversions:	
R = 5.678 x RSI	U = 1 / RSI

Effective Thermal Resistance of Above Ground Opaque Building Assemblies (RSI)				
Assembly	w/ HRV	w/o HRV	Proposed	Office Use
Ceilings below attics	10.43	10.43		
Cathedral / Flat roofs	5.02	5.02		
Walls & Rim joists	3.08	3.85		
Floors over unheated spaces	5.02			
Floors over garage	4.86			
Thermal Characteristics of Fenestration, Doors and Skylights (U)				
Assembly	Efficiency		Proposed	Office Use
Windows & Doors	Maximum U-Value = 1.40 or Minimum Energy Rating \geq 29			
One door exception	Maximum U-Value = 2.60			
Attic hatch	Maximum U-Value = 2.60			
Skylights	Maximum U-Value = 2.40			
Effective Thermal Resistance of Below-Grade or In-Contact-With-Ground Opaque Buildings Assemblies (RSI)				
Assembly	w/ HRV	w/o HRV	Proposed	Office Use
Foundation Walls	2.98	3.46		
Slab On Grade With Integral Footing	2.84	2.84		
Unheated floors: (does not apply to crawl spaces)				
Below Frost Line	uninsulated	uninsulated		
Above Frost Line	1.96	1.96		
Heated Floors	2.84	2.84		

Calculations of RSI_{eff} for the above assemblies are required to be submitted.

HVAC Equipment Performance Requirements				
Equipment	Capacity KW	Standard	Min. Efficiency	Proposed
Gas Fired Furnace w or w/o A/C	≤ 65.9	CSA P.2	AFUE $\geq 92\%$	
	> 65.9 & ≤ 117.23	CAN/CSA-P.8	$E_t \geq 78.5\%$	
Electric Boiler	≤ 88	(1)		
Gas Fired Boiler	≤ 88	CSA P.2	AFUE $\geq 90\%$	
	> 88 & ≤ 117.23	AHRI BTS	$E_t \geq 83\%$	
Other				
Heat Loss / Gain Calculations	<input type="checkbox"/> Calculations were prepared in conformance with CSA F280-12			BTU: _____
Nomenclature	AFUE= annual fuel utilization efficiency, E_t = thermal efficiency			
Water Heaters Performance Requirements				
Equipment	Capacity KW	Standard	Min. Efficiency	Proposed
Tank Storage Electric	≤ 12 kW (50 L to 270 L capacity)	CAN/CSA-C191	SL $\leq 35 + 0.20V$ (top inlet)	
			SL $\leq 40 + 0.20V$ (bottom inlet)	
	≤ 12 kW (> 270 L and ≤ 454 L capacity)		SL $\leq (0.472V) - 38.5$ (top inlet)	
			SL $\leq (0.472V) - 33.5$ (bottom inlet)	
> 12 kW (> 75 L capacity)	ANSI Z21.10.3/CSA 4.3 & DOE 10 CFR, Part 431, Subpart G	$S = 0.30 + 27 / V_m$		
Tank Storage Gas Fired	< 22 kW	CAN/CSA-P.3	EF $\geq 0.67 - 0.0005V$	
	≥ 22 kW	ANSI Z21.10.3/CSA 4.3	$E_t \geq 80\%$ and standby loss \leq rated Input/(800 + 16.57)(\sqrt{V})	
Tankless Gas Fired	≤ 73.2 kW	CAN/CSA-P.7	EF ≥ 0.8	
	> 73.2 kW	ANSI Z21.10.3/CSA 4.3 and DOE 10 CFR, Part 431, Subpart G	$E_t \geq 80\%$	
Tankless Electric	No standard addresses the performance efficiency; however, their efficiency typically approaches 100%			
Other				
Nomenclature	EF = energy factor in %/h, E_t = thermal efficiency S = standby loss in %h, SL = standby loss in W, V = volume V_m = measured storage volume in US gallons			

(1) Must be equipped with automatic water temperature control. No standard addresses the performance efficiency; however, their efficiency typically approaches 100%.